

BISTABLE RELAY with switch off timer BIS-410i


WARRANTY. The F&F products are covered by a warranty of the 24 months from the date of purchase. Effective only with proof of purchase. Contact your dealer or directly with us. More information how to make a complaint can be found on the website: www.fif.com.pl/reklamacja



Do not dispose of this device to a garbage bin with other unsorted waste! In accordance with the Waste Electrical and Electronic Equipment Act any household electro-waste can be turned in free of charge and in any quantity to a collection point established for this purpose, as well as to the store in the event of purchasing new equipment (as per the old for new rule, regardless of brand). Electro-waste thrown in the garbage bin or abandoned in the bosom of nature pose a threat to the environment and human health.


Purpose

Electronic bistable impulse relay allows switching of lighting or other equipment from several different points of using the control buttons are connected in parallel.



Relay version "i" is to pin adapted to cooperate with the receivers with high starting current, such as LED fluorescent lamps, ESL fluorescent lamps, electronic transformers, discharge lamps, etc.

Wiring diagram




Power table

incandescent	halogen	fluorescent	energy-saving	LED
2000W	1250W	1000W	500W	250W

The above data are indicative and will depend to a large extent on the design of a specific receiver (especially for LED bulbs, energy saving lamps, electronic transformers and pulse power supplies), switching frequency and working conditions. For more information visit: www.fif.com.pl.

Functioning

The receiver is followed by current pulse triggered by pressing any (bell) connected to the relay. Turning off the receiver will be the next pulse or automatically turn off after a preset time. Longer duration (minimum 2 seconds) pressing the relay instantaneous permanently. It will cut out after a momentary button is pressed again (or after a power failure).



Assembly

1. Disconnect the power supply.
2. The relay mounted in flush-mounted box.
3. Connect the power supply to a group of PWR: L phase wire to terminal 5 or 6. The N neutral to terminal 3 or 4.
4. Parallel momentary switches connected to terminal 1 and the L phase conductor.
5. Powered receiver connected in series to terminal 2 and the N neutral conductor.
6. Potentiometer to set the switch-off time.

Note

BIS-410 can be used with illuminated buttons.



Specifications

power supply	100±265V AC
contact / load current AC-1	1NO / <16A (160A/20ms)
current control pulse L	<5mA
response delay	0.1±0.2s
off time - adjustable	1±15min.
supply signalling	green LED
power consumption	
standby	0.15W
on	0.6W
working temperature	-25±50°C
terminal	2.5mm² screw terminals
tightening torque	0.4Nm
dimensions	Ø54 (□48×43mm), h= 20mm
mounting	in the Ø60 flush-mounted box
ingress protection	IP20