



SIA „Bureau Veritas Latvia”
Dunties street 17a, Riga, LV-1005, Latvia

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Nr. 16/080

This certificate applies to the product:

Electrical wiring conduits for civil, public and industrial building construction.
Corrugated (flexible), plastic conduits for electrical installation from halogen-free plastic:

EVOEL FL-0H – SMART
EVOEL FM-0H – SMART
EVOEL FMs-0H – SMART

Corrugated (flexible), plastic conduits with UV stabilized housing for electrical installation from halogen-free plastic:

EVOEL FMs – UV - 0H - SMART
EVOEL FHs – UV - 0H - SMART

(characteristics are detailed in the attached annex)

produced in the manufacturing plant

SIA "EVOPIPES"

Langervaldes street 2a, Jelgava, LV-3002, Latvia

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in standards

LVS EN 61386-1:2009 „Conduit systems for cable management.
Part 1: General requirements (IEC 61386-1:2008)”

and

LVS EN 61386-22:2004 +AC/A11:2011 „Conduit systems for cable management.
Part 22: Particular requirements - Pliable conduit systems”

under system „1+”, based on initial assessment and approval of the factory production control and product type initial testing with continuous surveillance including assessment and evaluation of factory production control and type testing, the performance set out in this certificate are applied and

product fulfills all the prescribed requirements set out above.

This certificate was first issued on **21/10/2016** and will remain valid till **20/10/2019** as long as product, standards, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Annex to certificate on 1 (one) page is integral part of this certificate.

To check the validity date of this certificate, please call +371 67323246.

Further clarification regarding the scope of this certificate and the applicability of the system requirements may be obtained by consulting to Bureau Veritas Latvia.

Certificate issued:

Riga, 28/10/2016

SIA „Bureau Veritas Latvia”
Member of the Board



Iveta Lazdiņa



**BUREAU
VERITAS**

SIA „Bureau Veritas Latvia”
Dunties street 17a, Riga, LV-1005, Latvia

Annex to certificate Nr. 16/080

28/10/2016

	Nominal size range, mm	Nominal mechanical (compression) strength class, N/5cm
EVOEL FL-0H – SMART	DN 16 - 50	320
EVOEL FM-0H – SMART		750
EVOEL FM_s-0H – SMART		750
EVOEL FM_s – UV - 0H - SMART		750
EVOEL FH_s – UV - 0H - SMART		1250

SIA „Bureau Veritas Latvia”
Member of the Board



Iveta Lazdiņa