

DECLARATION OF CONFORMITY No 214a/5/08

On the base of supervision carried out for all activities affecting the quality of our products in accordance with Company's Quality Assurance System based on ISO 9001:2008 and on the base of carried out the following tests,

We: **TECHNOKABEL S.A.**
Nasielska 55, 04-343 Warsaw, Poland

declare with a full responsibility that products/types:

**Fire resistant halogen free power cables
for operating voltage up to 0,6/1 kV**

Types:

**NHXH FE180 PH30/E30; NHXH-J FE180 PH30/E30; NHXCH FE180 PH30/E30
NHXH FE180 PH90/E90; NHXH-J FE180 PH90/E90; NHXCH FE180 PH90/E90
NHXHX FE180 PH90/E90; NHXHX-J FE180 PH90/E90; NHXCHX FE180 PH90/E90;
NHXHRHX FE180 PH30/E30; NHXHRHX FE180 PH90/E90
(N)HXH FE180 PH30/E30; (N)HXH-J FE180 PH30/E30; (N)HXCH FE180 PH30/E30
(N)HXH FE180 PH90/E90; (N)HXH-J FE180 PH90/E90; (N)HXCH FE180 PH90/E90**


this statement are applicable to comply with the following normative documents:

Polish Standards:	AT-0603-0064/2006/2012;, PN-HD 604 S1; PN-EN 60332-3-24, PN-EN 50268-2-3
Technical Documentation:	WT-TK-44
German standards:	DIN VDE 0266, DIN 4102 cz.12
International standards:	IEC 60332-3-24

conformity with the rules of Low Voltage Directives:

2006/95/WE	European Parliament and Council Directive of 12 December 2006 on the harmonization of the laws of Member States relating to electrical equipment designed for use within certain voltage limits.
-------------------	---

Warsaw, 04 November 2014

P R E S I D E N T

.....Marian Gelmata.....
(Signature, name and post of the person
authorised to draw up the declaration)